

Office of the Secretary
District Health & Family Welfare Samiti &
Chief Medical Officer of Health, Barasat, North 24 Parganas, Kol-124
Ph. No.2552-3129 E-mail: cmohn24pgs@gmail.com

Notice Inviting Quotation No: 04/E/2017-18

Memo No.DH&FWS/NHM/2017 /1432

Date: 12/07/17

Sealed Quotation is invited by the undersigned in the letterhead from the bonafide, responsible contractors for "Electrical Installation Work at the office of SMO, Madhyamgram RH", North 24 Parganas. Detailed information is available at the Engineering Section of CMOH Office, District Hospital campus, North 24 Parganas.

Eligibility Criteria and Terms & Condition

1. Agencies must be apply in their printed official pad including self attested Valid Trade License, P. Tax Challan, PAN Card and Electrical Supervisory license / Certificate.
2. 10% security deposit will be deducted from bills, and same will be refunded after 3 (Three) months from the date of hand over.

Schedule (Date & Time)

1. Last date for dropping of sealed Quotation on **20.07.2017 upto 2.00 PM** in the drop box at the office of the undersigned.
2. Sealed Quotation are should be opened on **20.07.2017 at 3.00 PM**.

Scope of Work

Sl. No.	Description of Item	Unit	Qty.
1	Distribution wiring in 1.1 KV single core stranded 'FR' PVC insulated & unsheathed copper wire (Brand approved by EIC) in 20mm size PVC rigid conduit 'FR' (Precision make) incl. necy. fittings as required		
	2 x 84/0.3 (6 sqmm) + 1 x 56/0.3 (4 sqmm) ECC	Mtr.	40
	2 x 56/0.3 (4 sqmm) + 1 x 36/0.3 (2.5 sqmm) ECC	Mtr.	10
	2 x 36/0.3 (2.5 sqmm) + 1 x 22/0.3 (1.5 sqmm) ECC	Mtr.	12
2	Supply, Installation and commissioning of 250V timer DB (equivalent of 8 way SPNDBin size) with steel sheet enclosed double door, phosphitised power coated neutral bar, Din rail with IP-43 protection comprised 1 no 20A/25A DPMCB (C curve, 10KA), 1 no 24 hours programmable timer switch with minimum switching time of 15 minutes and 1 no 18A/25A contractor, single phase screw type motor starter (compact- 25A- min) complete with internal wiring by suitable size of copper wire including 1 no auto manual by pass MCB changer over switch and provision for earthing attachment including LED indicating light or running condition with locking arrangement (for 1.5/2.0 Ton) Make- Siemens/L&T/ABB/Hager) (For AC)	Each	1
3	Supplying and fixing 240/415 V MCB Isolator on din rail of existing DBs and necessary connection	Each	1
4	Supplying and fixing 240/415 V MCB of Breaking capacity 10kA & C characteristics on din rail of existing DBs and necessary connection (SP MCB, 6-32A)	Each	2


Secretary

District Health & Family Welfare Samiti &
Chief Medical Officer of Health
North 24 Parganas


Memo No. DH&FWS/NHM/2017 / 1432/118)

Date: 12/07/2017

Copy forwarded for information and necessary action please to:

1. The District Magistrate, North 24 Parganas.
2. The PO& Dy. Secretary, NHM, H&FWS, Govt. of West Bengal.
3. The Dy. CMOH-I, Nodal Officer, N24 Pgs.
4. The Account Officer, CMOH Office, N24 Pgs.
5. The Admin. Officer, CMOH Office, N24 Pgs.
6. The BMOH, Mdhyamgram RH, N24 Pgs.
7. The DPMU Section, DH&FWS, N24Pgs.
8. Guard File


Secretary

 District Health & Family Welfare Samiti &
Chief Medical Officer of Health
North 24 Parganas